

Approved as amended in.....
 subject to conditions mentioned in Annexure 'A'
 of letter No. BNU/J.R. No. 2856/23-32024 गरीब
 S. No./G. No./CTS No. ६६ (गरीब) गरीब/बिनास कर-५
 Dated ०५/०६/२०२४
 for Metropolitan Commissioner and
Chief Executive Officer
 Pune Metropolitan Regional Development Authority, Pune.

WATER CAPACITY CALCULATIONS	
FOR RESIDENTIAL BUILDINGS	= NO. OF PERSONS/ FLAT X NO. OF FLATS X 90 = 5 X 9000 X 90 = 4,08,600 LITERS
SHOPS	= NO. OF PERSONS X 45 = 7,338.243 X 45 = 1,10,074 LITERS
TOTAL	= 5,18,674 LITERS
ADD FOR FIRE FIGHTING	= 20,000.4 BLDGS = 80,000 LITERS
REQD CAPACITY OF O.H.T.	= 5,98,674 LITERS
REQD CAPACITY OF UG WATER TANK	= 5,98,674 L.T.S = 8,98,011 L.T.
PROP. CAPACITY OF O.H.T.	= 8,98,011 LITERS
PROP. CAPACITY OF UG WATER TANK	= 8,98,011 LITERS

R.C.C. COPING
 BRICK WORK PANELS
 IN BETWEEN RCC COLUMNS
 RCC COLUMNS
 APPROX 3.00 m O/C

G.L.

Typical Compound Wall Section

